

To: Tom Sancken Attn: W. Raffensperger

From: Bruce A. Hucker By: Tom Hufnagel

Subject: Project Report Information *

Date: July 23, 2004


* FAP 326 (IL 47)

Section (111CS)W & RS-2, 1

Grundy County P-93-058-02 D3 # 1514

Upon review of the proposed project there have been no reports of flooding although there is a drainage problem just south of North St. on the west side of the road. It appears that an additional inlet is required.

If you have any questions, please contact Tom Hufnagel at ext. 8418.





TH:bb

S:\Operations\Huf\Project Report Information\IL 47, Benton to Main in Morris.doc